

Ann Lloyd CBE, Cadeirydd | Chair

☎ 01633 435 957

✉ Ann.Lloyd@wales.nhs.uk

Nicola Prygodzicz, Prif Weithredwr | Chief Executive

☎ 01633 435 958 🐦 CEOabuhb

✉ Nicola.Prygodzicz@wales.nhs.uk



GIG
CYMRU
NHS
WALES

Bwrdd Iechyd Prifysgol
Aneurin Bevan
University Health Board

Our ref: FOI 24-114

Monday, 29 January 2024

Thank you for your request to Aneurin Bevan University Health Board for information under the Freedom of Information Act (2000) received on Thursday 11th January 2024.

Your request

You requested the following:

Under the Data Protection Act 2018 I would like to make a freedom of information request for the location of;

The Grange University Hospital, Caerleon Rd, Llanfrechfa, Cwmbran. NP44 8YN.

I would like to request you answer the following questions;

1. Why are some of the external lamp posts led lights turning blue?
2. Is this because of the phosphorus coating?
3. Has the Hospital got the overall responsibility for the maintenance of these led lamp posts, and can you provide details of who to correspond with, if not, provide the details of who has the responsibility?
4. Has there been a risk assessment to identify and eliminate any potential harmful effects to the human body?
5. If a risk assessment has been completed, please provide details of where a copy can be requested?
6. Who manufactures these lights?
7. What is the make and model of these lighting assets?

Our Response

I can confirm that the Health Board has completed a search of its records and has established that it does hold information in relation to your request below:

1. We believe there is an issue with the LED rendering on the lamps.
2. No phosphorus coating on LED lights.
3. Yes, the hospital has got the overall responsibility for the maintenance of these LED lamp posts - Ross Andrews, Estates Manager.
4. No.
5. Not applicable.

Bwrdd Iechyd Prifysgol Aneurin Bevan
Pencadlys, Ysbyty Sant Cadoc
Ffordd Y Lodj, Caerllion, Casnewydd NP18 3XQ

☎ 01633 436 700 📘 BwrddIechydPrifysgol 🐦 BIPAneurinBevan

Dyfodol Clinigol
Clinical Futures

☎ 01633 436 700 📘 AneurinBevanHealthBoard 🐦 AneurinBevanUHB

Rydym yn croesawu gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg heb oedi.
Bwrdd Iechyd Prifysgol Aneurin Bevan yw enw gweithredol Bwrdd Iechyd Lleol Prifysgol Aneurin Bevan.

We welcome correspondence in Welsh and we will respond in Welsh without delay.
Aneurin Bevan University Health Board is the operational name of Aneurin Bevan University Local Health Board.

6. Lights manufactured by Holophane – a latent defect notification was issued some time ago to the main contractor (Lang O'Rourke). A chase email was sent recently and the aftersales team have promised a resolution imminently.
7. Make and mode of these lighting assets is Holophane FTS.2.LA084.AY