

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BRYNGLAS  
**DATE:** 22.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
B001 CLINIC	Ceiling Walls Floors Floor tiles	Plaster Plaster Vinyl tile (brown) Sample 36 photo 38
B002	Ceiling Walls Floors	Plaster Plaster Vinyl tile (orange)
B003	Ceiling Walls Floors Toilet cistern	Plaster Tile/brickwork Ceramic tiles Bakalite
B004 BATHROOM	Ceiling Walls Floors	Plaster Plaster and tile Teratzo
B005	Ceiling Walls Floors	Plaster Plaster and wall paper Vinyl tile (orange)
B006	Ceiling Walls Floors	Plaster Plaster and wall paper Vinyl tile (brown)
BA1 CORRIDOR	Ceiling Walls Floors	Plaster Plaster Vinyl tile (orange)
B007	Ceiling Walls Floors Radiator	Plaster Plaster and wall paper Vinyl tile Covered
B008	Ceiling Walls Floors Radiator	Plaster Plaster and wall paper Vinyl tile (light brown and blue) Covered
B009	Ceiling Walls Floors Radiator	Plaster Plaster and wall paper Vinyl sheet (orange) Covered
B010	Ceiling Walls Floors Radiator	Plaster Plaster and wall paper Vinyl tile Covered

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BRYNGLAS  
**DATE:** 22.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
B011	Ceiling Walls Floors	Plaster Plaster and wall paper Vinyl tile (light brown)
B012	Ceiling Walls Floors	Plaster Plaster on partition and solid Vinyl tile (light brown)
B013 AND B013A	Ceiling Walls Floors	Plaster Plaster Vinyl sheet
B026	Ceiling Walls Floors	Plaster Plaster Vinyl tile (cream) same as A026
B014	Ceiling Walls Floors Radiator	Plaster Plaster Vinyl tile (cream) Covered
B015 BATH	Ceiling Walls Floors Radiator	Plaster Plaster Vinyl tile Covered
B016 WC	Ceiling Walls Floors Radiator	Plaster Plaster and tile Vinyl sheet Covered
B017 DAY ROOM	Ceiling Walls Floors	Plaster Plaster and wall paper/below T and G panel Vinyl tile
B019 AND 18	Ceiling Walls Floors	Plaster Plaster Vinyl tile
B020 AND B02A	Ceiling Walls Floors	Ceiling tiles, mica board Plaster and tiled Vinyl sheet
B027 CORRIDOR	Ceiling Walls Floors Floor tile	Plaster Plaster and wall paper Vinyl tile carpet Sample 37 photo 39

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BRYNGLAS  
**DATE:** 22.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
B021	Ceiling Walls Floors	Plaster Plaster and wall paper Carpet
B022	Ceiling Walls Floors Floor tile	Plaster Plaster Vinyl tile Sample 38 photo 40
B023	Ceiling Walls Floors	Plaster Plaster and wall paper Carpet
B02 STAIRWELL	Ceiling Walls Floors	Plaster Plaster Teratzo
B024A	Ceiling Walls Floors Toilet Cistern	Plaster/concrete Plaster and brickwork painted Vinyl tile Bakalite

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S-C-14

LOCATION: BRYNGLAS

DATE: 22/02/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Boo1 Clinic		Ceiling Plaster
		WALLS Plaster
	(Floor Tile Sample No 36) Photo No 38	Floor Vinyl Tile (orange)
Boo2		Ceiling Plaster
		WALLS Plaster
		Floor Vinyl Tile (orange)
Boo3		Ceiling Plaster
		WALLS Tile / Brickwork
		Floor Ceramic Tiles
		Toilet Cistern Bakelite
Boo4 Bathroom		Ceiling Plaster
		WALLS Plaster & Tile
		Floor TERRAZO
Boo5		Ceiling Plaster
		WALLS Plaster & Wall Paper
		Floor Vinyl Tile (orange)

SHEET NO. 1

SIGNED: 

DATE: 22/02/2001

# ASBESTOS SURVEY REPORT SHEET


PREMISES: S.C.H

LOCATION: Bryn Glas

DATE: 22/02/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Boo6		Ceiling Plaster
		Walls Plaster + wall Paper
		Floor Vinyl Tile (Brown)
BA1 Corridor		Ceiling Plaster
		Walls Plaster
		Floor Vinyl Tile (Orange)
Boo7		Ceiling Plaster
		Walls Plaster + wall Paper
		Floor Vinyl Tile RADIATOR covered
Boo8		Ceiling Plaster
		Walls Plaster + wall Paper
		Floor Vinyl Tile LIGHT Brown + Blue RADIATOR covered
Boo9		Ceiling Plaster
		Walls Plaster + wall Paper
		Floor Vinyl Sheet (orange) RADIATOR covered
Boo0		Ceiling Plaster
		Walls Plaster + wall Paper
		Floor Vinyl Tile RADIATOR covered

SHEET NO. 2

SIGNED: 

DATE: 22/01/2001

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C. 4

LOCATION: BRUGLAS

DATE: 22/02/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Bo 11		Ceiling Plastered Walls Plastered + self paper Floor Vinyl Tile (cream)
Bo 12		Ceiling Plastered Walls Plaster on partition + solid Floor Vinyl Tile Light Green
Bo 13 Bo 13A		Ceiling Plastered Walls Plastered Floor Vinyl Sheet
Bo 26		Ceiling Plastered Walls Plastered Floor Vinyl Tile (cream) <sup>part</sup>
Bo 14 (wash)		Ceiling Plastered Walls Plastered Floor Vinyl Tile (cream) Radiator Covered.

SHEET NO. 3

SIGNED: 

DATE: 22/02/2001

# ASBESTOS SURVEY REPORT SHEET


PREMISES: 3.2.2.4

LOCATION: Weymouth

DATE: 22/02/2001

ROOM/ROOM NO.	SAMPLES TAKEN		COMMENTS	
	YES	NO		
B027 Corridor	Sample No 37 Floor Tile		Ceiling	Plastered
			Walls	Plastered with Paper
			Floor	Vinyl Tile Carpet
B021			Ceiling	Plastered
			Walls	Plastered with Paper
			Floor	CARPET
B022			Ceiling	Plaster
			Walls	Plaster
	Sample taken Floor Tile No 38 Photo 40		Floor	Vinyl Tile
B023			Ceiling	Plaster
			Walls	Plaster with Paper
			Floor	Carpet
B02 Stair well			Ceiling	Plaster
			Walls	Plaster
			Floor	TERAZO
B024 W.C.			Ceiling	Plaster/Concrete
			Walls	Plaster + Brickwork Painted
			Floor	Vinyl Tile
			Toilet Cister	FRANKLIN

SHEET NO. 5

SIGNED: 

DATE: 22/02/2001

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BETTWS WARD  
**DATE:** 22.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A001	Ceiling Walls Floors	Plaster Plaster/partition plasterboard Vinyl sheet
A024 UNDERSTAIRS	Ceiling Walls Floors	Concrete Brickwork Concrete
A001A	Ceiling Walls Floors Floor tile	Plaster Plaster on partition and solid Vinyl tile Sample 32 photo 34
A002 FEMALE WC	Ceiling Walls Floors	Plaster Plaster on partition and solid Vinyl tile
A003 WAITING ROOM	Ceiling Walls Floors	Plaster Plaster Vinyl tile
A004 NO OFFICE	Ceiling Walls Floors	Plaster Plaster Vinyl tile
A025 CORRIDOR	Ceiling Walls Floors	Plaster Plaster Vinyl tile
A005	Ceiling Walls Floors	Plaster Plaster Vinyl tile (beige and brown)
A006	Ceiling Walls Floors Radiator	Plaster Plaster Vinyl tile (blue) Covered
A007	Ceiling Walls Floors Radiator	Plaster Plaster Vinyl tile (blue) Covered
A008	Ceiling Walls Floors Radiator	Plaster Plaster Vinyl tile (blue) Covered

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BETTWS WARD  
**DATE:** 22.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A026 CORRIDOR	Ceiling Walls Floors Floor tile	Plaster Plaster Vinyl tile (cream) Sample 33 photo 35
A012 WASH	Ceiling Walls Floors	Plaster Plaster and tile Vinyl tile (cream)
A013 BATH	Ceiling Walls Floors	Plaster Plaster and tile Vinyl tile (cream)
A009	Ceiling Walls Floors Floor tile	Plaster Plaster Vinyl tile (blue) Sample 33 photo 35
A010/011	Ceiling Walls Floors Radiator	Mica board ceiling tiles, ceiling void entered Plaster Carpet Covered
A015 MAIN OFFICE	Ceiling Walls Floors	Plaster Plaster and T and G/wallpaper Carpet
A027 CORRIDOR	Ceiling Walls Floors	Plaster Plaster and wallpaper (pipework boxing wood) Vinyl sheet
A016 KITCHEN 016A	Ceiling Walls Floors Floor Sink Pad	Plaster Plaster and tile Vinyl floor (black and grey) Tile sample no 35 photo 37 Sample no 34 photo 36
A017 OFFICE	Ceiling Walls Floors Pipework Boxing	Plaster Plaster Vinyl tile (cream and grey) Wood
A018	Ceiling Walls Floors	No access
A019	Ceiling Walls Floors	Plaster Plaster Vinyl tile

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** BETTWS WARD  
**DATE:** 22.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A020 CLINIC	Ceiling Walls Floors	Plaster Plaster Vinyl tile (grey blue)
A028 STAIRWELL	Ceiling Walls Floors	Plaster Plaster Teratzo
A021 WC	Ceiling Walls Floors	Concrete Brickwork painted Teratzo
A023 WC	Toilet	Unable to open door

# ASBESTOS SURVEY REPORT SHEET

AO 23 Toilet unable to open door.


PREMISES: S.C.H

LOCATION: Berrus wa

DATE: 22/1/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A001		Ceiling Plaster WALLS Plaster / Partition Plaster Board Floor Vinyl Sheet
A024 under stairs		Ceiling Concrete WALLS Brickwork Floor Concrete
A001a		Ceiling Plaster WALLS Plaster / on Partition + Solid Floor Vinyl Tile
	Photo 34 Sample N° 32 Floor Tile	
A002 Female W.C	1.	Ceiling Plaster WALLS Plaster / on Partition + Solid Floor Vinyl Tile
A003 Warrant Rm		Ceiling Plaster WALLS Plaster Floor Vinyl Tile
A004 No office		Ceiling Plaster WALLS Plaster Floor Vinyl Tile

SHEET NO. 1

SIGNED: 

DATE: 22/01/2001

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: Bettws ward

DATE: 22/2/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A025 Corridor		Ceiling Plaster Walls Plaster Floor Vinyl Tile
A005		Ceiling Plaster Walls Plaster Floor Vinyl Tile (Beige + Brown)
A006		Ceiling Plaster Walls Plaster Floor Vinyl Tile (Blue) Radiator (covered)
A007		Ceiling Plaster Walls Plaster Floor Vinyl Tile (Blue) Radiator (covered)
A008		Ceiling Plaster Walls Plaster Floor Vinyl Tile (Blue) Radiator (covered)

SHEET NO. 2

SIGNED: 

DATE: \_\_\_\_\_

# ASBESTOS SURVEY REPORT SHEET

PREMISES: \_\_\_\_\_

LOCATION: \_\_\_\_\_

DATE: \_\_\_\_\_

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A026 Corridor		Ceiling Plaster
		WALLS Plaster
	Sample No 33 (Photo 35)	Floor Vinyl Tile (cream)
A012 Wash		Ceiling Plaster
		WALLS Plaster + Tile
		Floor Vinyl Tile (cream)
A013 Bath		Ceiling Plaster
		WALLS Plaster + Tile
		Floor Vinyl Tile (cream)
A014 W.C.		Ceiling Plaster
		WALLS Plaster + Tile
		Floor Vinyl Sheet / Terazo
		Three No Toilet Cistern Bakelite <small>Same as previous sample</small>
A009		Ceiling Plaster
		WALLS Plaster
		Floor Vinyl Tile (Blue)

SHEET NO. 3

SIGNED: \_\_\_\_\_

DATE: \_\_\_\_\_

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: BETTWS WARD

DATE: 22/2/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A010 / Hall		Ceiling (MICA BOARD Ceiling Tiles) <small>Ceiling void entered</small> WALLS Plastered Floor. CARPET RADIATOR (covered)
A015 main office		Ceiling Plaster WALLS Plaster + T+G / wallpaper Floor CARPET
A027 Corridor		Ceiling Plaster WALLS Plaster + wallpaper <small>(Pie work Boring wood)</small> Floor Vinyl SHEET
A016 KITCHEN	(Sink Pad Sample No 34) PHOTO No 36 Floor Tile Sample No 35 (w/Photo 37)	Ceiling Plaster
A016a		WALLS Plaster + Tile
		Floor Vinyl Floor (Black + Grey)
A017 office		Ceiling Plaster WALLS Plaster Floor Vinyl Tile (CREAM + Grey) Pie work Boring wood

SHEET NO. 4

SIGNED: 

DATE: 22/2/2001

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: BETWIS WALS.

DATE: 22/02/2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
A018	NO ACCESS	Ceiling Walls Floor
A019		Ceiling PLASTER WALLS PLASTER Floor Vinyl Tile
A020 CLINIC		Ceiling PLASTER WALLS PLASTER Floor Vinyl Tile (Grey Blue)
A028 Stairwell		Ceiling PLASTER WALLS PLASTER Floor TERRAZO
A021 W.C.		Ceiling CONCRETE WALLS BRICKWORK PAINTED Floor TERRAZO

SHEET NO. 5

SIGNED: 

DATE: 22/2/2001

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** MALE BARRACKS  
**DATE:** 23.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 101	Ceiling Walls Floors No samples taken	Plastered Plastered Vinyl and ply
ROOM 102		As room 101
ROOM 103	Ceiling Walls Floors No samples taken	Plastered Plastered and papered Carpet
ROOM 104	Ceiling Walls Floors Sample 43 photo 46	Plastered Papered Vinyl sheet
ROOM 105	Ceiling Walls Floors No samples taken	Plasterboard with fibreboard coating? Papered Carpet
ROOM 106		As room 105
ROOM 107		As room 105
ROOM 108	Ceiling Walls Floors No samples taken	Plastered Papered Carpet
ROOM 109	Ceiling Walls Floors No samples taken	Papered Papered Carpet
ROOM 110	Ceiling Walls Floors No samples taken	Papered Papered Carpet
ROOM 113	Ceiling Walls Floors No samples taken	Plastered Plastered Vinyl sheet
ROOM 114		As room 113
ROOM 116		As room 113

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** MALE BARRACKS  
**DATE:** 23.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 116A		As room 113
ROOM 115		As room 113
ROOM 111 PROJECTION ROOM	Ceiling/Floor Walls Slate from Roof Sample 44 photo 48	Concrete Brickwork Adjacent to Room 111
ROOM 112	No samples taken *However, asbestos fire blanket present - container clearly labelled P47	As room 111
ROOF SPACE	No samples taken	Traditional roof construction with MMF insulation

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** FEMALE BARRACKS  
**DATE:** 23.01.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 117/118 (NOW ONE ROOM)	Ceiling Walls Floors No samples taken	Papered on solid Papered on solid Carpet
ROOM 119	Ceiling Walls Floors No samples taken	Papered Plastered Vinyl sheet
ROOM 120		As room 117/118
ROOM 121	Ceiling Walls Floors No samples taken	Plastered Plastered Bare floorboards
ROOM 122		As room 117/118
ROOM 124	Ceiling Walls Floors Sink Pad	Papered Papered and ceramic tile Vinyl sheet Sample 45 photo 49
ROOM 125		As room 117/118
ROOM 126		As room 117/118
ROOM 123		As room 117/118
ROOM 127		As room 117/118
ROOM 128		As room 117/118
ROOM 129	Ceiling/Walls Floor No Sample taken	Plastered Vinyl
ROOM 130		As room 129
ROOM 131 CORRIDOR	Ceiling Walls Floors No samples taken	Papered on solid Papered on solid Carpet
ROOF SPACE	No samples taken	Traditional construction with MMF insulation

# ASBESTOS SURVEY REPORT SHEET


PREMISES: Male Barracks

LOCATION: St. Cadors

DATE: 23-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS	
Room 101	No Samples Taken	Ceiling	— Plastered
		Walls	— Plastered
		Floor	— Vinyl & Ply
Room 102	"	As Room 101	
Room 103	"	Ceiling	— Plastered
		Walls	— Plastered & Papered
		Floor	— Carpet
Room 104	Sample N°43 PK6	to Sink Pad	
		Ceiling	— Plastered
		Walls	— Papered
		Floor	— Vinyl Sheet
Room 105	No Samples Taken	Ceiling	— Plasterboard with fibroboard coating?
		Walls	— Papered
		Floors	— Carpet.
Room 106	"	As Room 105	
Room 107	"	"	
Room 108	"	Ceiling	— Plastered
		Walls	— Papered
		Floor	— Carpet.

SHEET NO. 1

SIGNED: 

DATE: 23-2-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: Male Barracks

LOCATION: St. Cadogan

DATE: 23-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 109	No Samples Taken	Ceiling - Papered Walls - Papered Floor - Carpet
Room 110	"	Ceiling - Plasterboard with fibrous paper surface Walls - Papered Floor - Carpet
Room 113	"	Ceiling - Plastered Walls - Plastered Floor - Vinyl Sheet
Room 114	"	As Room 113
Room 116	"	As Room 113
Room 116a	"	As Room 113
Room 115	"	As Room 113
Room 111 (Projection Room)	"	Ceiling / Floor - Concrete Walls - Brickwork
Room 112	Sample N° 44 PK8 No Samples Taken	Slate from roof adjacent to Room 111 As Room 111
	* However Asbestos fire blanket present - container clearly labelled PK7	
Roof Space	No Samples Taken	Traditional Roof Construction with MUF insulation

SHEET NO. 2

SIGNED: 

DATE: 23-2-01

# ASELSTOS SURVEY REPORT SHEET

PREMISES: Female Barracks

LOCATION: St. Cadzow

DATE: 23-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 117 & 118 (Now one room)	No Samples Taken	Ceiling — Papered on Solid Walls — Papered on Solid Floor — Carpet
Room 119	"	Ceiling — Papered Walls — Plastered Floor — Vinyl Sheet
Room 120	"	As room 117/118
Room 121	"	Ceiling — Plastered Walls — Plastered Floor — Bare Floorboards
Room 122	"	As room 117/118
Room 123 & 4	Sample N°45 P49	Sink Pad Ceiling — Papered Walls — Papered & Ceramic Tiles Floor — Vinyl Sheet
Room 124 & 5	No Samples Taken	As room 117/118
Room 125 & 6	"	As room 117/118
Room 123	"	As room 117/118
Room 127	"	As room 117/118
Room 128	"	As room 117/118
Room 129	"	Ceiling/Walls — Plastered Floor — Vinyl
Room 130	"	As room 129
Room 131		

SHEET NO. 1

SIGNED: 

DATE: 23-2-01



## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** CLUB (GROUND FLOOR)  
**DATE:** 23.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 032	Floor Ceiling Walls Sample no 47 photo 51	Tile Plastered Brickwork
ROOM 031	Ceiling Walls Floor Toilet cistern	Plastered Brickwork Tiles as room 032 Sample 48 photo 52
ROOM 030	Ceiling Walls Floor Toilet cistern	Plastered Brickwork Tiles as room 032 Same as room 031
ROOM 029	Floor Walls Roof Samples	Tiles (both samples of floor tiles) Brickwork Timber sarking underside on traditional roof construction Sample 49 photo P1 and sample 51 photo P4
ROOM 028 AND 028A	Roof Walls Floor No samples taken	As room 029 Timber frame on dwarf brick wall Concrete
ROOM 027	Ceiling Walls Floor No samples taken	Lath and plaster Brickwork and ceramic tiling Concrete
ROOM 026	Floor Ceiling Walls Samples Note:	Tile Fibreboard sheet on timber frame Timber partition Sample 50 photo P2 Room 026 (bar) built within room 025
ROOM 025	Ceiling Walls Floor Note: P3	Plasterboard underside to traditional roof construction Brickwork Concrete Steel vent shaft accessed through ceiling - some hardboard lining Large electrical isolator switch (Royal make)

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** CLUB (FIRST FLOOR)  
**DATE:** 23.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 145 SMOKE ROOM	Floor Roof Walls Sample no 46 photo 50	Tile Timber sarking underside on traditional roof construction Brickwork with plywood and glass partition to one side

# ASBESTOS SURVEY REPORT SHEET


PREMISES: Club (Ground Floor)

LOCATION: St. Cadoc's

DATE: 23-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 032	Sample N°47 P51	Floor Tile
		Ceiling - Plastered
		Walls - Brickwork
Room 031	Sample N°48 P52	Toilet Cistern
		Ceiling - Plastered
		Walls - Brickwork
		Floor - Tiles as Room 032
Room 030	No Samples Taken	Toilet Cistern same as Room 031
		Ceiling - Plastered
		Walls - Brickwork
		Floor - Tiles as Room 032
Room 029	Samples N°49 P1 & N°51 P4	Floor Tiles (Both samples of floor tiles)
		Roof - Timber sarking underside on traditional roof construction
		Walls - Brickwork
Room 028 & 028a	No Samples Taken	Roof - as Room 029
		Walls - Timber frame on dwarf brick wall
		Floor - Concrete
Room 027	No Samples Taken	Ceiling - lath & plaster
		Walls - Brickwork & ceramic tiling
		Floor - Concrete

SHEET NO. 1

SIGNED: 

DATE: 23-2-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: Club (Ground Floor)

LOCATION: St. Cadoc's

DATE: 26-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 026	Sample N°50 P2	Floor Tile
		Ceiling - fibreboard sheet on timber frame
		Walls - timber partition
		*Note: Room 026 (part) built within Room 025
Room 025	No Samples Taken	Ceiling - plasterboard underside to
		traditional roof construction
		Walls - brickwork
		Floor - concrete
		*Note - steel vent shaft accessed
		through ceiling - some hardboard
		lining.
	P3	large electrical isolator switch (Royal Make)

SHEET NO. 2.

SIGNED: 

DATE: 26-2-01



## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** ITU  
**DATE:** 26.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 0117A	Ceiling Walls Floor No samples taken	Plasterboard (one skylight) Brickwork Vinyl tiles
ROOM 0117	Ceiling Walls Floor No samples taken	No ceiling - open to roof of room 0118 Brickwork Vinyl tiles (same as 0117A)
ROOM 0118	Floor Walls Roof Sample no 52 photo 5	Tiles (same as 0117 and 0117A) Brickwork Steel construction
ROOMS 0119/0120/0121/ 0122/0123	Ceiling/Walls Floor No samples taken	Plastered Ceramic tiles
ROOM 0124	Ceiling/Walls Floor No samples taken	Plastered Carpet
ROOM 0125		As room 0124
ROOM 0126	Floor Ceiling No samples taken	Timber and glass partition within room 0118 Tiles as room 0118 No ceiling - open to roof of 0118
ROOM 0127		As room 0124
ROOM 0128	Floor Ceiling/Walls Sample no 53 photo 6	Tiles (same as in 0129) Plastered
ROOM 0129		As room 0128
CORRIDOR 0130	Floor Ceiling/Walls Sample no 54 photo 7	Tiles Plastered - 3 skylights
CUPBOARD 0130A	No samples taken	Cupboard contains electrical distribution units. Nothing suspicious apparent

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** ITU  
**DATE:** 26.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
TOILET AREA 0131	Ceiling Walls Floor No samples taken	Lean to outside toilet entrances Timber sarking to underside of traditional roof construction Brickwork Vinyl sheet
WC'S 13 A/B/C	Ceiling/Walls Floor Roof No samples taken	Plastered Vinyl sheet Space above toilets unsuspecting
ROOM 0132	Ceiling Walls Floor Floor Level Roof No samples taken	Timber sarking to underside of traditional roof construction Brickwork Parquet blocks Window to one wall boarded over with mica board One skylight in roof
ROOM 0133	No samples taken	As room 132 save carpet tiles over floor and aforementioned window replaced with one large pane of glass
ROOM 0134	Ceiling Walls Floor No samples taken	Timber sarking to underside of traditional roof construction Brickwork and plaster on solid Vinyl sheet
ROOM 0135		As above - 0134
ROOM 0136		As above - 0134 save carpet on floor
ROOM 0136A	Ceiling Walls Floor No samples taken	Plasterboard Brick and stud partitioning Carpet on parquet block (Room is stud partitioning built within room 0136)
ROOM 0137	Ceiling Walls Floor Sample no 55 photo 8	Artex on plasterboard Paper on plasterboard, dry lining on brick Parquet blocks
ROOM 0138	Ceiling Walls Floor Sink Pad	Plasterboard under traditional roof Brickwork and plaster on solid and plasterboard partition Vinyl sheet Sample no 56 photo 9
ROOM 0138A	Ceiling/Floor Walls No samples taken	Concrete Brickwork

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** ITU  
**DATE:** 26.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 0139	No samples taken	As room no 0138 save bare concrete floor
ROOM 0140	Ceiling Walls Floor No samples taken	Concrete Brick and block work Concrete
ROOM 0141		As room 0140
ROOM 0142	Ceiling Walls Floor No samples taken	Sarking and traditional roof Brickwork Concrete
ROOM 0143		As room 0142
ROOM 0143A		As room 0142
ROOM 0144		As room 0142
ROOM 0144A		As room 0142 save plasterboard to underside of roof
ROOM 0145	Ceiling Walls Floor No samples taken	Plastered Brickwork Concrete
ROOM 0146		As room 0145
ROOM 0147		Gasket around boiler Room fabric as 0145 Sample no 57 photo 10
ROOM 0147A	Ceiling Walls Floor No samples taken	Plastered Brick and ceramic tiles Concrete

# ASBESTOS SURVEY REPORT SHEET

PREMISES: I.T.U.

LOCATION: St. Cadoc's

DATE: 26-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 0117a	No Samples Taken	Ceiling - Plasterboard (one skylight) Walls - Brickwork Floor - Vinyl Tiles
Room 0117	"	No ceiling - open to roof of 0118 Walls - Brickwork Floor - Vinyl Tiles (same as 0117a)
Room 0118	Sample N°52 P5	Floor Tile (same as 0117 & 0117a) Walls - Brickwork Roof - Steel Construction
Rooms 0119/0120 0121/0122/0123	No Samples Taken	Ceiling/Walls - Plastered Floor - Ceramic Tiles
Room 0124	"	Ceiling/Walls - Plastered Floor - Carpet
Room 0125	"	As room 0124
Room 0126	"	Timber & Glass partition within room 0118 Floor Tiles as room 0118
Room 0127	"	No ceiling - open to roof of 0118 As Room 0124
Room 0128	Sample N°53 P6	Floor Tile (the same are in 0129) Ceiling/Walls - Plastered
Room 0129	"	As Room 0128
Corridor 0130	Sample N°54 P7	Floor Tile Ceiling/Walls - Plastered - 3 skylights

SHEET NO. 1

SIGNED: 

DATE: 26-2-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: ITU & HORIZON

LOCATION: St. Cadoc's

DATE: 26-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Cupboard 0130a	No Samples Taken	Cupboard contains electrical distribution units. Nothing suspicious apparent.
Toilet Area 131	No Samples Taken	lean to outside toilet entrance Ceiling - Timber sarking to underside of traditional Roof Construction Walls - Brickwork Floor - Vinyl Sheet
W.C.'s 131a / b / c	"	Ceiling / Wall - Plastered Floor - Vinyl Sheet
Room 132	"	Roof space above toilets unsuspecting Ceiling - Timber sarking to underside of traditional Roof Construction Walls - Brickwork Floor - Parquet Blocks Floor level window to one wall boarded over with micaboard. One large skylight in roof
Room 133	"	As Room 132 save carpet tiles over floor and aforementioned window replaced with one large pane of glass

SHEET NO. 2

SIGNED: 

DATE: 26-2-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: Horizon

LOCATION: St. Cadoc's

DATE: 26-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 0134	No Samples Taken	Ceiling - Timber sarking to underside of traditional roof construction. Walls - brickwork & plaster on solid Floor - Vinyl sheet.
Room 0135	"	As above - 0134.
Room 0136	"	As above - 0134 save carpet on floor.
Room 0136a	"	Ceiling - Plasterboard Walls - Brick & Stud Partitioning Floor - Carpet on Parquet Block. (Room is Stud Partitioning built within Room 0136)
Room 0137	Sample N°55 P8	Ceiling Artex on Plasterboard Walls - Paper on Plasterboard dry lining on brick. Floor - Parquet Blocks
Room 0138		Ceiling - Plasterboard under / traditional roof Walls - Brickwork & Plaster on Solid & Plasterboard Partition Floor - Vinyl Sheet.
	Sample N°56 P9	Sink Pad
Room 0138a	No Samples Taken	Ceiling / Floor - concrete Walls - brickwork
Room 0139	No Samples Taken	As room N°0138 save bare concrete floor.

SHEET NO. 3

SIGNED: 

DATE: 26-2-01

# ASBESTOS SURVEY REPORT SHEET


PREMISES: Horizon

LOCATION: St. Cadocs

DATE: 26-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 0140	No Samples Taken	Ceiling - Concrete Walls - Brick & Block work Floor - Concrete
Room 0141	"	As above room 0140
Room 0142	"	Ceiling - Sarking & Traditional Roof Walls - Brickwork Floor - Concrete
Platform 0143	"	As 0142
Room 0143a	"	As 0142
Room 0144	"	As 0142
Room 0144a	"	As 0142 save plasterboard to underside of roof
Room 0145	"	Ceiling - Plastered Walls - Brickwork Floor - Concrete
Room 0146	"	As room 0145
Room 0147	Sample N°57 P10	Gasket around border Room fabric as 0145
Room 0147a	No Samples Taken	Ceiling - Plastered Walls - Brick & Ceramic Tiles Floor - Concrete

SHEET NO. 4

SIGNED: 

DATE: 26-2-01

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** MORTUARY  
**DATE:** 27.02.01

<b>ROOM/ROOM NO.</b>	<b>SAMPLES TAKEN YES/NO</b>	<b>COMMENTS</b>
PATHOLOGY	Ceiling No Walls No Floor No Roof Void	Fibre board tile Brick/tiles Vinyl sheet Accessed
HOLDING ROOM 1	Ceiling No Walls No Floor No	Fibre board tile Brick/wooden panels Carpet
HOLDING ROOM 2	Ceiling No Walls No Floor No	Fibre board tile Brick Vinyl sheet
CHAPEL	Ceiling No Walls No Floor No Roof Void	Lath and plaster Plastered/paper Wooden blocks/carpet Accessed



## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** OUTBUILDING  
**DATE:** 27.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
GARDENERS/TRACTOR SHED/INCINERATOR ROOM 146	Ceiling No Walls No Floor No	Concrete Brick Concrete
BATTERY CHARGING 0153/0152	Roof No Walls No Floor No	Corrugated tin Brick Concrete
MAIN GAS VALVE 150	Roof sample 59 photo 13 Walls No Floor No Gasket sample 58 photo 12	Corrugated sheet/plasterboard Brick Concrete Suspect
GARAGE 0148	Roof No Walls No Floor No	Lath and plaster Brick Concrete
DILTANK BUNDS 147	Yes sample 61 photo 15	Gasket x 3

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S. C. H

LOCATION: Out Building

DATE: 27.2.2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
GARDEN WALK		
TRACTOR SHED	NO	Ceiling - CONCRETE.
INCINERATOR ROOM	NO	WALLS - BRICK
146	NO	FLOOR - CONCRETE.
BIOLOGY CHANGE	"	Roof - CORRUGATED TIN.
0153/0152	"	WALLS - BRICK
	"	FLOOR - CONCRETE
HAIN GAS VALVE	YES SAMPLE # 59 PHOTO 13	Roof - CORRUGATED SHEET / PLASTER BOARD.
0150	NO	WALLS - BRICK
	NO	FLOOR - CONCRETE.
	YES SAMPLE # 58 PHOTO 12	GASKET - SUSPECT
GARAGE 0148	NO	Roof - WATH + PLASTER.
	"	WALLS - BRICK
	"	FLOOR - CONCRETE
DILTANK BUNDS 147	YES SAMPLE # 61 PHOTO 15	GASKET x 3

SHEET NO. 1

SIGNED: MP

DATE: 27.2.2001

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** PSYCHOLOGY BLOCK  
**DATE:** 27.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 133 W/C	Ceiling Walls Floors	Lath and plaster Plastered Vinyl sheet
ROOM 133A		As above
ROOM 134	Ceiling Walls Floors	Lath and plaster Papered Carpet
ROOM 135		As above
ROOM 136		As above
ROOM 137		As above
ROOM 138		As above
ROOM 139		As above
ROOM 140	Roof void accessed	As above All clear
ROOM 141	Roof void accessed	As above All clear

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: Psychology Block

DATE: 27.2.2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Roof 133 w/c		Corley - LATH + Plaster, Walls - Plasterboard Floors - Vinyl Tiles
" 133 A		AS ABOVE.
" 134		AS ABOVE Plasterboard Floor - Carpet.
" 135		AS ABOVE.
" 136		" "
" 137		" "
" 138		" "
" 139		" "
" 140		" "
	Roof Joist Accessed	ALL CLEAR.
> 141		" "
	" " "	ALL CLEAR.

SHEET NO. 1

SIGNED: MP

DATE: 27.2.2001

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** MAIN STORES  
**DATE:** 27.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 033 OFFICE	Ceiling No Walls No Floors No	Wood boarding Wood boarding/plaster Wooden blocks
ROOM 034		As above
ROOM 035 COLD ROOM	No	PVC panelled
	No	Floor vinyl sheet

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** CORRIDORS FIRST FLOOR  
**DATE:** 20.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
CORRIDOR 148A	No No Sample 20 photo 21	Ceiling - lath and plaster Walls - plaster Floors - vinyl tiles old type
	No Accessed	Ceiling - ceiling tiles fibre board Ceiling void accessed
LIFT ROOM 1/2	Roof Walls Floor	Corrugated steel Brick Concrete
ROOM 1	Yes sample no 60 photo 14	Brake shoe - suspect
ROOM 2	No sample taken but assumed as (1) brake shoe suspect	
GROVE B123		(L & P wooden)



## ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: CORRIDORS 1<sup>st</sup> Floor

DATE: 20.2.2001

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS:
<u>CORRIDOR 148 A</u>	<u>NO</u>	<u>CEILING - LATH + PLASTER</u>
	<u>NO</u>	<u>WALLS - PLASTERED.</u>
	<u>SAMPLE 20 PHOTO 21</u>	<u>FLOORS - VINYL TILES. OLD TYPE</u>
	<u>NO</u>	<u>CEILING - Corky Tiles FIBRE BOARD.</u>
	<u>Accessories.</u>	<u>CEILING VOID ACCESSED.</u>
<u>LIFT ROOM 1/2</u>		<u>ROOF - CORRUGATED STEEL</u>
		<u>WALLS - BRICK</u>
		<u>FLOOR - CONCRETE.</u>
<u>Room 1</u>	<u>YES SAMPLE No 60 PHOTO 14</u>	<u>BRAKE SHOE - SUSPECT.</u>
<u>" 2</u>	<u>NO " TAKEN BUT ASUMED AS(1)</u>	<u>" " "</u>
<u>(Glove B123)</u>		<u>(L+P PL woodens)</u>

SHEET NO. \_\_\_\_\_

SIGNED: \_\_\_\_\_

DATED: \_\_\_\_\_

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** ENGINEERING AND BUILDERS YARD  
**DATE:** 27.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 001 OFFICE	Ceiling No Walls No Floor No	Match boarding Match boarding Wooden blocks/carpet tiles
ROOM 001 OFFICE	Ceiling No Walls No Floor No Ceiling Void	Plasterboard Plastered Carpet Accessed
ROOM 003	Ceiling No Walls No Yes Sample no 64 photo 18	Plasterboard Plastered/plaster board Capet tiles/old vinyl tiles
ROOM 004	Ceiling No Walls No Floor No	Wood Brick Concrete
ROOM 005	Ceiling Walls Floor	Panel timber Brick painted Concrete
ROOM 006 & 007	Ceiling Walls Floor Fuse box	Panel timber Brick painted Concrete/wood block Photo 19
ROOM 12 AND 12A	Ceiling Walls Floor	Loft accessed, plaster Plaster/ceramic tiles Terrazzo
ROOM 13 AND 14	Ceiling Walls Floor	Plaster Ceramic tile/plaster Concrete
ROOM 154 SWITCH ROOM GENERATOR	Ceiling Walls Floor Vinyl tile	Wood panel Brick Concrete Sample 65 photo 20
ROOM 155		As room 154 except vinyl tile floor
ROOM 156 MESS ROOM	Ceiling Walls Floor Sink Pad	As 154 Brick/plywood Vinyl tiles Sample 66 photo 21
ROOM 157	Ceiling Walls Floor	As 154 Brick/plywood Concrete

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** ENGINEERING AND BUILDERS YARD  
**DATE:** 28.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 158		As room 157
ROOM 159		As room 157
ROOM 160	Ceiling Walls Floor Toilet Cistern	As 154 Brick painted Vinyl tiles Sample 67 photo 22
ROOM 161	Ceiling Walls Floor	Asbestos tiles sample 68 photo 23 Brick Vinyl tiles
ROOM 162 CORRIDOR	Ceiling Walls Floor	Asbestos tiles Brick plywood Vinyl tiles
ROOM 163	Ceiling Walls Floor	Concrete Brick Concrete
ROOM 164, 165, 166 & 167	Ceiling Walls Floor Sample room 167	Concrete Brick Concrete Sample 69 photo 24 photo 25
ROOM 168 MEDICAL GASES	Ceiling Walls Floor	Timber Brick Concrete
ROOM 008	Ceiling Walls Floor Attic	Plaster Plaster Vinyl Area inspected
ROOM 009	Ceiling Walls Floor	Plaster Plaster Vinyl
ROOM 010	Ceiling Walls Floor	Timber/plaster Plaster/ceramic tile Concrete/vinyl
ROOM 15	Ceiling Walls Floor Existing Soffit Floor Tile Cistern	Plaster Plaster Vinyl tiles Sample 70 photo 26 Sample 72 photo 28 Sample 71 photo 27

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** ENGINEERING AND BUILDERS YARD  
**DATE:** 28.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 21	Ceiling Walls Floor	Plaster/timber Plaster Wood
ROOM 22	Ceiling Accessed Ceiling Walls Floors	Yes Fibreboard Plaster Carpet
ROOM 23	Ceiling Accessed Ceiling Walls Floors	Yes Fibreboard Plaster Vinyl
ROOM 24		As room 22
ROOM 16, 18, 19 & 20	Ceiling Walls Floors Sink Pad (Room 20)	Insulation board Insulation board Wood Sample 73 photo 29
ROOM 17	Ceiling Walls Floor	Insulation board Ceramic tiles Terrazzo tiles

# ASBESTOS SURVEY REPORT SHEET

PREMISES: S.C.H

LOCATION: BUILDING YARD

DATE: 27.2.2001

ROOM/ROOM NO	SAMPLES TAKEN YES/NO	COMMENTS
Room 001 office	No	Ceily - MATCH BOARD
	"	WALLS - " "
	"	FLOOR - WOODEN BLOCKS / CARPET TILES.
" 002	"	Ceily - PLASTER BOARD
	"	WALLS - PLASTER
	"	FLOOR - CARPET.
	"	Ceily void - ACCESSIBLE.
" 003	"	Ceily - PLASTER BOARD.
	"	WALLS - PLASTER / P. BOARD
	Two Samples No. 6 & Photo 18.	FLOOR - CARPET TILES / OAK VINYL TILES
" 004	NO	Ceily - Wood
	NO	WALLS - BRICK
	NO	FLOOR - CONCRETE
Rm 005		Ceiling Panel Timber
		Walls brick painted
		FLOOR. Concrete.
Rm 006 & 007	Fuse box Photo 19	Ceiling Panel Timber
		Walls brick painted
		FLOOR Concrete / Wood block

SHEET NO. 1

SIGNED: M P x AJAllen

DATE: 28.2.01.

# ASBESTOS SURVEY REPORT SHEET

EMG &

PREMISES: 6041

LOCATION: BUILDERS YARD

DATE: 28.2.01

ROOM/ROOM NO	SAMPLES TAKEN YES/NO		COMMENTS	
RM 12 & 12a			Ceiling	Left Accessed. Plaster
			Walls	Plaster / Ceramic Tile
			Floors	Terrazzo
RM 13 & 14			Ceiling	Plaster
			Walls	Ceramic tile / Plaster
			Floors	Concrete
RM 154			Ceiling	Wood Panel
Switch Room			Walls	Brick
Generator	Vinyl Tile Sample	Sample 65	Floors	Concrete
		Photo 20		
RM 155	As 154			
	except vinyl tile floor.			
RM 156	Sink pad Sample	Sample 66	Ceiling	As 154
Mess Rm		Photo 21	Walls	Brick / Plywood
			Floors	Vinyl Tile
RM 157			Ceiling	As 154
			Walls	Brick / Plywood
			Floors	Concrete

SHEET NO. 2

SIGNED: AJAHEN

DATE: 28.2.01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCH

LOCATION: EMG & BUILD YARD

DATE: 28-2-01

ROOM/ROOM NO	SAMPLES TAKEN YES/NO		COMMENTS	
RM 158			AS 157	
RM 159			AS 157	
RM 160	Toilet System	Sample 67	Ceiling	AS 154
		Photo 22	Walls	brick painted
			Floors	Vinyl tile
RM 161		Sample 68	Ceiling	Asbestos Tiles ?
		Photo 23	Walls	brick
			Floors	Vinyl tiles
RM 162			Ceiling	Asbestos tile
Corridor			Walls	brick Plywood
			Floors	Vinyl Tile
RM 163			Ceiling	Concrete
			Walls	brick
			Floors	Concrete
RM 164, 165 & 166	Sample RM 167	Sample 69	Ceiling	Concrete
167		Photo 24	Walls	brick
		Photo 25	Floors	Concrete

SHEET NO. 3

SIGNED: AJ Allen

DATE: 28-02-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCU

LOCATION: ENG & BUILD YARD

DATE: 28-2-01

ROOM/ROOM NO	SAMPLES TAKEN YES/NO	COMMENTS
RM 168		Ceiling Timber
Medical Gases		Walls Brick
		Floors Concrete
RM 008	Attic area inspected.	Ceiling Plaster
		Walls Plaster
		Floors Vinyl.
RM 009		Ceiling Plaster
		Walls Plaster
		Floors Vinyl
RM 010		Ceiling Timber / Plaster
		Walls Plaster / Ceramic tile
		Floors Concrete. / Vinyl
RM 15	Sample taken of exterior soffit	Ceiling Plaster
	Sample 70	Walls Plaster
	Photo 26	Floors Vinyl tile
	Floor tile	
	Sample 72	
	Photo 28	
	Cistern	
	Sample 71	
	Photo 27	

SHEET NO. 4

SIGNED: AJ Allen

DATE: 29-02-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCH

LOCATION: EMG 1 BUILD YARD

DATE: 28.2.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO		COMMENTS
RM 21			Ceiling Plaster / Timber
			Walls Plaster
			Floors Wood
RM 22			Ceiling Accessed YES
			Ceiling Fibre board
			Walls Plaster
			Floors Carpet.
RM 23			Ceiling Accessed YES.
			Ceiling Fibre board.
			Walls Plaster
			Floors Vinyl.
RM 24	AS RM22		
RM 16, 18, 19 & 20	Sample RM 20 (Sink Pan)	Sample 73	Ceiling Insulation Board.
		Photo 29	Walls Insulation Board.
			Floor Wood.
RM 17			Ceiling Insulation Board.
			Walls Ceramic tile
			Floor Terrazzo tile

SHEET NO. 5

SIGNED: AJ Allen

DATE: 28.2.01

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOCS HOSPITAL  
**LOCATION:** MAIN BUILDING  
**DATE:** 28.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 36	Ceiling Walls Floors Cistern	Plaster Plaster Vinyl Sample 74 photo 30
ROOM 37 SHOP	Ceiling Walls Floor	Timber infill between aluminium beams Dry lined with chipboard Vinyl tiles
ROOM 38	Ceiling Walls Floor	Plaster Plaster Carpet
ROOM 39	Ceiling Walls Floors Sample 75 photo 31	Plaster/papered Plaster Vinyl Sample of roof felt on walkway between lobby and tea room
ROOM 40	Ceiling Walls Floor	Plaster Paper Carpet
ROOM 41	Ceiling Walls Floor	Plaster Paper Carpet
ROOM 42	Ceiling Walls Floors Floor Tile	Brick/plaster Plaster Vinyl tiles Sample 76 photo 32
ROOM 43	Ceiling Walls Floor	Plaster Paper Carpet
ROOM 44	Ceiling Walls Floor	Plaster Paper Carpet
ROOM 45	Ceiling Accessed Walls Floors Floor Tile	Yes - fibreboard tiles Plaster Vinyl tiles, ceramic tiles Sample 77 photo 33
ROOM 46 & 47	Ceiling Walls Floor	Papered Plaster Carpet

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** MAIN BUILDING  
**DATE:** 28.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
ROOM 49	Ceiling Walls Floor	Plastered/papered Plastered/papered Carpet
ROOMS 49, 50, 51, 52, 53 and 54	Ceiling Walls Floor	Fibreboard tile Plastered/papered Vinyl sheet
SKYLIGHT IN 54		Ply
ROOM 55	Ceiling Walls Floor	Suspended fibreboard tiles, unsuspecting void Plaster and ceramic tiles Vinyl and ceramic tiles
056 LIFT SHAFT		
ROOM 057	Ceiling Walls Floor	Plaster Papered on solid Wood block
ROOM 057A	Ceiling Walls Floor	Plaster Plaster Concrete
ROOM 058	Ceiling Walls Floor	Plaster Plaster and wood panel Vinyl sheet
ROOM 059	Ceiling Walls Floor	Plasterboard Brick/ply Concrete/vinyl
ROOM 060	Ceiling Walls Floor	Underside and door/*slates, sample No 79 P35/No 80*P36 Brick Concrete
061 LIFT SHAFT		
ROOM 062	Ceiling Walls Floor	Plaster Plaster and ceramic tiles Terrazzo
ROOM 063	Ceiling Walls Floor	Open to traditional roof structure Plaster and wood panelling Timber boards
ROOM 064	Ceiling Walls Floor	Plaster Plaster and wood panelling Terrazzo

## ASBESTOS SURVEY REPORT SHEET

**PREMISES:** ST CADOC'S HOSPITAL  
**LOCATION:** MAIN BUILDING  
**DATE:** 28.02.01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
STAGE AREA 063A (BELOW STAGE)	Ceiling Walls Floor	Foil sheeting to underside of timber stage Brick Concrete
STAGE AREA 063A (ABOVE STAGE)	Walls Floor Rear of Stage	Plaster Timber boards Lagging - sample 78 P 34
ROOM 066	Ceiling Walls Floor	Plaster Plaster and ceramic tile Carpet
ROOM 068	Ceiling Walls Floor Toilet Area Attic Space	Plaster Paper on solid Carpet Plastered ceiling and walls and concrete floor Unsuspectious
ROOM 069	Ceiling Walls Floor	Suspended clear tiles Plastered Vinyl sheet
ROOM 070	Ceiling Walls Floor	Plastered Plastered/tiled Quarry tiles
ROOM 071	Yes No 81 P 37	As above room 070 * panel above main entrance micaboard above fume exhaust screen to side of room

\* Note: 065 and 067 are open courtyard areas

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCH

LOCATION: MAIN BUILDING

DATE: 28-2-01

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
RM 34 W/C	Cistern Sample      Sample 74 Photo 30	Ceiling      Plaster Walls      Plaster Floors      Vinyl
RM 37 SHOP	<del>Has</del> Access	Ceiling - Timber infill between aluminium beams Walls - Dry lined with chipboard Floors - Vinyl Tiles
RM 38		Ceiling      Plaster Walls      Plaster Floors      Carpet
RM 39 LOBBY	Sample of Roof felt      Sample 75 on walkway between      Photo 31 Lobby and Tea Room.	Ceiling      Plaster/Papered Walls      Plaster Floor      Vinyl
RM 40		Ceiling      Plastered Walls      Papered Floors      Carpet

SHEET NO. 1

SIGNED: AJ Allen

DATE: 28-2-01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCH

LOCATION: MAIN BUILDING

DATE: 28.2.01.

ROOM/ROOM NO	SAMPLES TAKEN YES/NO	COMMENTS
RM 41		Ceiling Plaster
		Walls Papered
		Floors Carpet
RM 42		Ceiling brick / Plaster
	Sample 76	Walls Plaster
	Floor Tile Sample. Photo 32	Floors Vinyl tiles
RM 43		Ceiling Plastered
		Walls Papered
		Floors Carpet
RM 44		Ceiling Plastered
		Walls Papered
		Floors Carpet
RM 45		Ceiling Accessed. YES Fibre board tiles
	Sample 77	Walls Plaster
	Floor Tile Photo 33	Floors Vinyl tiles, Ceramic tiles

SHEET NO. 2

SIGNED: AJ Allen

DATE: 28.2.01.

# ASBESTOS SURVEY REPORT SHEET

PREMISES: SCH

LOCATION: MAIN BUILDING

DATE: 28-2-01

ROOM/ROOM NO	SAMPLES TAKEN YES/NO	COMMENTS
RM 46 & 47		Ceiling Papered
		Walls Plaster
		Floor Carpet
RM 49	<del>NO</del> ACCESS	Ceiling Plastoflex / Papered
		Walls " "
		Floor CARPET.
RM 49 / 50 / 51 / 52	<del>NO</del> ACCESS	Ceiling - FIBRE BOARD TILES.
53 / 54		Walls - Plastoflex / Papered.
		Floor - Vinyl Tiles.
SKYLIGHT IN 54		PLY

SHEET NO. 3

SIGNED: AJAHEN

DATE: 28 2 01

# ASBESTOS SURVEY REPORT SHEET

PREMISES: St. Cadoc's

LOCATION: Main Building

DATE: 1-3-2

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 055	No	Ceiling - Suspended Fibreboard Tiles Unsuspectious Void
		Walls - Plaster & Ceramic Tiles
		Floor - Vinyl & Ceramic Tiles
056 (LIFT shaft)		
Room 057	No	Ceiling - Plaster
		Walls - Papered on solid
		Floor - Wood Block
Room 057a	No	Ceiling - Plaster
		Walls - Plaster
		Floor - Concrete
Area 058	No	Ceiling - Plaster
		Walls - Plaster & Wood Panel
		Floor - Vinyl Sheet
Room 059		Ceiling - Plaster Board
		WALLS - BRICK / Ply.
		Floors - CONCRETE / Vinyl
Room 060	Yes N <sup>o</sup> 79 P35 / N <sup>o</sup> 80* P36	Ceiling - Underside of Dec / * Slates
		Walls - BRICK
		Floor - CONCRETE
061 (LIFT shaft)		

SHEET NO. 4

SIGNED: 

DATE: 1-3-2

# ASBESTOS SURVEY REPORT SHEET

PREMISES: St. Cadocs

LOCATION: Main Building

DATE: 1-3-2

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS	
Room 062	No	Ceiling - Plaster Walls - Plaster & Ceramic Tiles Floor - Terrazzo	
Room 063	No	Ceiling - Open to Traditional Roof Structure Walls - Plaster & Wood Panelling Floor - Timber boards	
Room 064	No	Ceiling - Plaster Walls - Plaster & Ceramic Tiles Floor - Terrazzo	
Stage area 063a	No	Ceiling - Foilsheeting to underside of timber stage Walls - Brick Floor - concrete	
			Below STAGE
			Above STAGE
		Ceiling - Open to Traditional Roof Structure Trap door at Apex - Walls - Plaster Floor - Timber boards lagging at rear of stage	
			Yes N°78 P34

SHEET NO. 5

SIGNED: 

DATE: 1-3-2

\* Note 065 & 067 are open  
Court yard areas

# ASBESTOS SURVEY REPORT SHEET

PREMISES: St. Cadocs

LOCATION: Main Building

DATE: 1-3-2

ROOM/ROOM NO.	SAMPLES TAKEN YES/NO	COMMENTS
Room 066	No	Ceiling - Plaster Walls - Plaster & Ceramic Tile Floor - Carpet
Room 068	No	Ceiling - Plaster Walls - Paper on solid Floor - Carpet (Toilet area off room has plastered ceiling and walls and concrete floor) Attic space unsuspecting
Room 069	NO	Ceiling - Suspended @ Luan Tiles. WALL - PLASTERED. Floor - Vinyl Tiles.
Room 070	No	Ceiling - PLASTERED WALLS - PLASTERED / TILED FLOOR - QUARRY TILES.
Room 071	<del>No</del> Yes * N°81 P37	As above Room 070 * Panel above main entrance Miraboard above fume exhaust screen to side of room

SHEET NO. 6

SIGNED: 

DATE: 1-3-2